


The Path to Zero: Ultra-efficient Architecture on the NREL Campus: S&TF and Master Planning



Nancy Carlisle, AIA
Director, Integrated Application Center, D&MT

World Renewable Energy Forum
May 14, 2012
Denver, Colorado

NREL/PR-7A40-55091

Presentation Outline

Objective. Describe the aspects of NREL's S&TF and Campus Master Planning in terms of how they have influenced ultra-efficient architecture on NREL's campus.

- **Science and Technology Facility**

- Processes that aided in accomplishing ultra-efficient objectives
- Building features
- Lessons learned

- **Sustainable Campus Planning Process**

- Key Features
- Lessons Learned

- **Conclusions**



Science and Technology Facility Project Overview




- Completed in August 2006, the lab is 71,347 ft².
- The lab is designed to accelerate renewable energy process and manufacturing research.
- Construction cost was \$22.7 million (\$318 gross ft²).
- Designed to IBC H5.
- Architect was the SmithGroup, Phoenix, AZ and general contractor is M.A. Mortenson.
- The first Federal LEED Platinum Building
- NREL's first LEED Platinum Building.

The RFP as a Tool to Accomplish Project Objectives

Equally-weighted objectives guided planning for the facility:

- Build a safe working environment for researchers
- Build a functional, flexible facility that encourages collaboration
- Meet aggressive goals for energy efficiency and sustainable design
- Complete the project within budget to achieve best value



NREL formed an IPT to select the A\E team and provide project oversight


Integrated Project Team (IPT) had representation from:

- Users
- ES&H
- Facilities Dept (cost and schedule)
- Energy perspective
- LEED\Image\Site




Understand Your Building Loads


**Skin-Load
Dominated (small
building in a cold
climate)**



**Internal-Load
Dominated
(large building
in any climate)**




**Ventilation &
Process-Load
Dominated
(any climate)**



H = Heating load **L** = Lighting load **C** = Cooling load

O = Other, including ventilation & plug loads

Floor Plans





First Floor

Separation of laboratories from offices allows greater energy efficiency and more natural lighting


Second Floor

Lab Cross-Section



Solar Orientation

Office section is oriented 7.5 degrees west of due south; the laboratories are 15 degrees east of true south. Both positions are near optimal for natural daylighting.



Office/Office Support Area



Computer Simulation



**The Office module
was designed for
100% ambient
daylighting between
10:00 am and 2:00 pm**



Photo Taken 2/10/06

Daylighting Commentary

- Ambient daylighting in the office area is glare free and provides even illumination.
- Views from the labs are a welcomed feature.
- Discussed cost trade offs of other types of shade structures (for future projects).
- Lighting controls integration was challenging.
- Perceived light pollution issue important to teach the occupants how to interact with their space.



Wing walls on the east




Office area with shade structure impacting view

S&TF Labs



The “Centerpiece” - 10,425 ft² Process Development and Integration Laboratory

Large view window with North and South clerstories in the PDIL



Pedestrian corridor allows views from labs on the south side

Service Corridor and Utilities



A 12 ft wide service corridor with “notches” for noise producing equipment



Utility trench from corridor into PDIL

Easy access to utilities for on-going maintenance is an important consideration in design (for energy savings and safety)

Energy Conservation Measures (ECMs)

In addition to VAV fume hoods -

- Lab ventilation air heat recovery (runaround loop)
- Fan coils for lab sensible cooling w/o requiring extra expensive conditioned OA
- Increased supply air temperatures
- Lab fan power minimization and exhaust fan staging
- High efficiency condensing boiler
- High efficiency VSD chiller
- Office under floor air system
- Evaporative cooling
- Process cooling water energy recovery to ventilation
- Daylighting controls for office & labs

ECM Results

Simple Paybacks for the Energy Efficiency Measures

Measure	Incremental Cost (\$)	Savings (\$/yr)	Payback (yrs)
VAV w/o HR	\$300,000	\$92,120*	3.3
Add HR	\$80,000	\$36,487	2.2
Lab supplementary cooling & raised primary SATs	\$150,000	\$14,873	10.1
Overhangs, & glazing		\$4,400	
Lighting power density		\$5,694	
Daylight controls	\$10,000	\$4,111	2.4
Office underfloor air & evap cooling	\$20,000	\$3,103	6.4
Chiller plant upgrades	\$33,000	\$12,607	2.6
Tower free cooling	\$60,000	\$6,754	8.9
Process CHW for preheat	\$48,000	\$4,752	10.1
Lab AHU evaporative	\$20,000	\$3,758	5.3
Fan pressure drops		\$19,064	
Fan staging	\$37,500	\$4,691	8.0
Boiler & DHW	\$24,000	\$8,972	2.7

* VAV included in the base case

ECM Results

**Simulated and Measured Energy performance for the S&TF –
24% less than Standard 90.1-2004 Appendix G Performance Method**

System	Simulated	Measured (4\07-3\08)	Measured 4\08-3\09)
Ventilation	9.6 kWh\gft ²	10.1 kWh\gft ²	10.5 kWh\gft ²
Cooling	4.8 kWh\gft ²	13.0 kWh\gft ²	11.9 kWh\gft ²
Lighting	2.3 kWh\gft ²		
Process\Plug	21.3 kWh\gft ²	15.7 kWh\gft ² ⁽¹⁾	17.6 kWh\gft ² ⁽¹⁾
Heating	91.9 kBtu\gft ²	136.7 kBtu\gft ²	132.7 kBtu\gft ²
Total (electric and gas)	223.4 kBtu\gft ²	269.0 kBtu\gft ²	269.0 kBtu\gft ² ⁽²⁾

- 1. Process\plug and lighting are combined**
- 2. In Oct 2010, we changed the humidity set point form 28% to 20% , this resulted in a reduction on natural gas use of 32% and a reduction in water use of 20%**

Note: we added a 94 KW PV system since the building was built

Taken from the Labs for the 21st Century S&TF Case Study (www.labs21century.gov)

Keys to Success

- Understanding how energy was used in the building –guided the building zoning.
- RFP as a design tool – specifically setting measurable energy\sustainability goals and criteria for A\E selection.
- Having “champions” committed to energy efficient design .
- Use building simulation as a tool in the design process
- Through measuring the performance overtime, we have been able to continue to find improvements in energy efficiency
- Energy savings strategies
 - Significant savings beyond VAV are technically & economically feasible
 - Indirect\direct evaporative climate works well in our climate.
 - Daylighting controls\zoning needed
 - Recent reduction in humidity level resulted in significant energy\water savings and researchers are content

Developed the NREL-wide Campus-wide General Development Vision in 2003

“NREL’s vision is to develop a world-renowned, high-performance research center that showcases energy technology innovation and leadership and embraces the best in energy and ecological conservation practices.” - James L. Spigarelli, President and CEO of the Midwest Research Institute

- Planning allows you to look at energy supply and demand as one integrated system.
- Campus planning establishes a framework for building orientation, transportation, parking, storm water management, campus amenities, establishing density, and maintaining open space.
- It provides opportunities for using renewables that go beyond the building boundaries.



Energy Goals for the NREL Campus

Demand reduction

- Understand how buildings use energy ; implement the cost-effective energy and water efficiency retrofits
- Use principles of energy efficiency and low energy design to reduce energy demand in all new construction
- Operate central plants efficiently
- Alternative transportation

Supply side options


- Use combined heat and power systems
- Use on-site renewables for demonstration and where it is cost-effective
- Buy green power (over the next 25 years) so that 100% of our power will be from renewable sources

NREL's Sustainable Campus Planning


Current Site and Facilities



NREL's Overall Campus Plan



NREL Campus On-site Renewable Energy





Developing a Sustainable Campus

- **Highly Efficient Buildings**
approaching net zero energy
- **Onsite Renewable Power**
Generation Capacity > 15 MW
 - PV arrays rated at 4.6 MW
 - Research turbines 10+ MW
 - Renewable Fuel Heating Plant
rated at 2.5 MW thermal
output
- **Alternatively Fueled Vehicle Fleet**


DEVELOPMENT PRIORITIES

- Safe, secure and sustainable
- Iconic facilities
- LEED Platinum/Gold certified facilities
- Carbon neutral
- Highly efficient, near-net zero energy
buildings
- Living Laboratory

Existing and Future Onsite PV at STM*




NREL Campus Build-out Vision as Living Lab



- RSF (office) and STF (lab) both LEED Platinum;
- Campus is a model of sustainability: Over 15 MW of Renewable energy (PV at 4.6 MW; 10 MW research turbines & 2.5 MW thermal)

What were the key factors that led to this innovative campus plan?

- Buy-in from the top
- Vision that recognizes and balances competing needs
- Consensus building regarding the plan (“Bring the right people together”)
- From the energy point of view – Hierarchy of Actions – People, Conservation; Renewables; Offsets
- A Portfolio of actions required for Deep Savings



Thank you!!

