



# Impacts of Regional Electricity Prices and Building Type on the Economics of Commercial Photovoltaic Systems

Sean Ong, Clinton Campbell, and Nathan Clark

NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency & Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.

**Technical Report**  
NREL/TP-6A20-56461  
December 2012

Contract No. DE-AC36-08GO28308

# **Impacts of Regional Electricity Prices and Building Type on the Economics of Commercial Photovoltaic Systems**

Sean Ong, Clinton Campbell, and Nathan Clark

Prepared under Task No. SM12.1031

NREL is a national laboratory of the U.S. Department of Energy, Office of Energy Efficiency & Renewable Energy, operated by the Alliance for Sustainable Energy, LLC.

National Renewable Energy Laboratory  
15013 Denver West Parkway  
Golden, Colorado 80401  
303-275-3000 • [www.nrel.gov](http://www.nrel.gov)

**Technical Report**  
NREL/TP-6A20-56461  
December 2012

Contract No. DE-AC36-08GO28308

## NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>

Available for a processing fee to U.S. Department of Energy  
and its contractors, in paper, from:

U.S. Department of Energy  
Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831-0062  
phone: 865.576.8401  
fax: 865.576.5728  
email: <mailto:reports@adonis.osti.gov>

Available for sale to the public, in paper, from:

U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
phone: 800.553.6847  
fax: 703.605.6900  
email: [orders@ntis.fedworld.gov](mailto:orders@ntis.fedworld.gov)  
online ordering: <http://www.ntis.gov/help/ordermethods.aspx>

Cover Photos: (left to right) PIX 16416, PIX 17423, PIX 16560, PIX 17613, PIX 17436, PIX 17721



Printed on paper containing at least 50% wastepaper, including 10% post consumer waste.


## Acknowledgments

This work was made possible by the Solar Energy Technologies Program at the U.S. Department of Energy (DOE). The authors wish to thank Paul Denholm, Elizabeth Doris, Trieu Mai, Nate Blair, and Robin Newmark of the National Renewable Energy Laboratory (NREL) for reviewing various versions of the document, as well as Henrietta de Veer (Prime Solutions, Inc.), Nicholas Bowden (Illinois State University), David Arfin (DOE), and Ammar Qusaibaty (DOE) for their thoughtful reviews. The authors also thank Mary Lukkonen of NREL's Communications Office for a thorough technical edit of the document. Finally, and naturally, any remaining errors are the fault of the authors.

## Executive Summary

Business owners often have a choice between multiple electricity rate options. For businesses with photovoltaic (PV) installations, choosing the right rate is essential to maximize the value of PV generation. The complex interaction between PV generation, building load, and rate structure makes determining the best rate a challenging task. We evaluated 207 rate structures across 77 locations and 16 commercial building types and identified the impacts of regional electricity prices and building type on the economics of solar PV systems. Results for expected solar value that result from bill savings are reported for all locations, building types, and rate structures evaluated. Aggregated results are also reported, showing general trends across various impact categories. Key findings include:

- **Regional electricity price differences are more important than building type when considering PV economics.** On average, system economic performance varies 30% by building type. Buildings with relatively large rooftop area and lower energy consumption tend to yield higher-than-average solar value. Regionally, PV system economics vary by a factor of 10, with the most economically attractive locations having the highest average electricity prices.
- **The best electricity rate for a business depends on the amount of PV capacity installed relative to the building's electricity load.** The rate structure that minimizes the business's electricity expenses prior to a PV installation still remains the best rate after a PV system is installed, as long as the system is small compared to the business's electric load. Other rates provide greater value than the initial rate for larger PV system sizes (see Figure ES-1 for an example).
- **Rate structure elements impact PV economic performance, with energy-only rates being most favorable.** On average, energy-only rates were found to increase solar value by 13%, versus rates with demand charges. Flat energy-only rates were found to be the most favorable, while rates that combined demand charges with tiered rates were found to be the least favorable.



**Figure ES-1. Value of PV generation under various rate structures and penetration levels for warehouses in the Wisconsin Electric Power territory**

Notes: Additional details for each rate type is provided in Appendix A. Dashed lines represent non-applicable rates for this building type.

# Table of Contents

<b>1</b>	<b>Introduction.....</b>	<b>1</b>
<b>2</b>	<b>Data and Methodology .....</b>	<b>2</b>
	2.1 Data and Methodology Overview .....	2
	2.2 Load Data.....	2
	2.3 Rate Data.....	6
	2.4 Solar Resource Data.....	8
	2.5 System Advisor Model and Technical Calculations .....	8
	2.6 Bill Savings and Solar Value Calculations .....	9
<b>3</b>	<b>Results.....</b>	<b>12</b>
	3.1 Net Value of Solar .....	12
	3.2 Impact of PV Building Penetration.....	16
<b>4</b>	<b>Conclusion .....</b>	<b>21</b>
	<b>References .....</b>	<b>22</b>
	<b>Appendix A .....</b>	<b>23</b>
	<b>Appendix B .....</b>	<b>30</b>
	<b>Appendix C: Digital Appendix .....</b>	<b>33</b>

## List of Figures

Figure 1. Locations of simulated building load data, shown within ASHRAE climate zones .....	3
Figure 2. Simulated hourly load data for medium-sized office buildings during the last week of March .....	5
Figure 3. Simualted hourly load data for medium-sized office buildings during the second week of July.....	5
Figure 4. Example of applicability of electricity rates for commercial facilities in three utility service territories in California .....	7
Figure 5. Value of PV generation under various rate structures and penetration levels for a school in the PG&E service territory .....	10
Figure 6. Net value of PV generation under various rate structures and penetration levels for a school in the PG&E service territory .....	11
Figure 7. Distribution of electricity prices and calculated solar values .....	12
Figure 8. Average solar value for each building type .....	13
Figure 9a. Average solar value for the top 39 locations .....	14
Figure 9b. Average solar value for the next 38 locations .....	15
Figure 10. Solar value by rate type, averaged across all locations and building types evaluated ..	16
Figure 11. Net solar value with respect to penetration for all Entergy Texas rates evaluated.....	18
Figure 12. Net solar value with respect to penetration for all PG&E rates evaluated .....	18
Figure 13. Distribution of optimal penetration levels for all locations and building types evaluated .....	19
Figure 14. Comparison of solar values relative to the highest solar value, averaged for all locations and building types.....	20

## List of Tables

Table 1. DOE Reference Buildings With Average Energy Consumption and Peak Power .....	4
Table 2. Summary of Rate Types Used in This Study.....	8
Table 3. Average PV Penetration Values by Building Type .....	17
Table A-1. List of Utilities and Rates Evaluated With Information About Their Rate Type, Average Price Without Solar, Average Maximum Solar Value, and Applicable Range .....	23
Table B-1. Maximum Solar Value Found for Each Building Type in Each Location .....	30



# 1 Introduction

Businesses are increasingly considering solar technologies as a way to help offset a portion of their annual energy expenditures. Many commercial buildings have large, flat roofs that could allow for solar photovoltaic (PV) systems capable of generating a significant portion of their annual electricity needs. However, the value of this generation is highly dependent on the business's electricity rate. Utilities often offer a choice between multiple rate options.

Understanding conditions for optimal solar value requires an analysis of the interaction between the building electric load, the amount of PV generation, and rate structure. The availability of high resolution data (i.e., hourly or sub-hourly resolution) is essential when determining the impacts of time-of-use (TOU) rates and demand charges. These considerations may present a challenging task for businesses that are trying to determine whether or not solar makes economic sense for their building. In this study, we evaluate the impacts of regional electricity prices and building type on the economics of solar PV systems.

A variety of analyses on the impacts of rate structures on the economics of PV systems have been conducted, including the evaluation of the residential sector (Darghouth et al. 2010) and commercial sector (Wiser et al. 2007) in California. Commercial rate structures have also been evaluated for specific building categories, such as office buildings (Ong et al. 2010) and schools (Ong and Denholm 2011). This report adds to the literature by providing a national-scale evaluation of the impacts of commercial rate structures across a variety of building categories.

In this study, 207 rate structures from 52 electric utilities are evaluated. These rate structures were used to assess solar value and annual savings for 16 different building types. Rate impacts are dependent on individual building load profiles, which vary from one location to another. PV performance trends and relative bill savings are reported across all rates, building types, and locations evaluated. These results are not intended to represent any specific customer. Businesses considering a solar installation should evaluate their facility's unique load profile and use this report as a guide to analyze the potential impacts of a PV system.

## 2 Data and Methodology

### 2.1 Data and Methodology Overview


The complex interaction between building load, solar production, and electricity rate structure requires a model that can simultaneously process all elements involved. The System Advisor Model (Section 2.5) is used to generate solar production and bill savings results from a variety of inputs, including: hourly building load data (Section 2.2), utility rate data (Section 2.3), and meteorological data (Section 2.4). The following sections provide details on the data and methodology used in this analysis.

### 2.2 Load Data

Building load datasets are important components in any rate structure analysis that includes demand charges and tiered rates. Demand charges (defined in Section 2.3) are usually based on the peak monthly power demand of a building; consequently, quantifying the demand reduction value of a PV system requires a load profile. Load profiles are also required when evaluating tiered rates and demand charges, where rates vary depending on monthly energy usage. This analysis uses load profile data for 16 building categories from the U.S. Department of Energy (DOE) commercial reference building models (Deru et al. 2011), which were simulated using the EnergyPlus simulation software.<sup>1</sup> All loads and buildings for the benchmark models were simulated under typical meteorological year 3 (TMY3) conditions. TMY3 is a dataset of the National Solar Radiation Database (Wilcox 2007; Wilcox and Marion 2008). For consistency, TMY3 conditions were also used when simulating PV performance. Section 2.4 contains more information about the TMY3 weather data. Load data were simulated for 77 locations throughout the United States. Locations were selected from the largest utilities in each state and chosen to represent all climate zones in the contiguous United States. Figure 1 shows the locations analyzed and official climate zones recognized by the American Society of Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE). Sixteen building categories were simulated for each of the 77 locations, resulting in 1,232 unique load profiles used in this analysis. Table 1 summarizes each building type used in this study.

---

<sup>1</sup> The reference buildings used in this study represent are based on current building codes and are not intended to represent older building construction. For more information on the EnergyPlus model, see <http://apps1.eere.energy.gov/buildings/energyplus/>.



**Figure 1. Locations of simulated building load data, shown within ASHRAE climate zones**


**Table 1. DOE Reference Buildings With Average Energy Consumption and Peak Power**

<b>Building Type</b>	<b>Floor Area (ft<sup>2</sup>)</b>	<b>Number of Floors</b>	<b>Annual Energy (MWh)</b>	<b>Peak Power (kW)</b>
Full-Service Restaurant	5,500	1	322	68
Hospital	241,351	5	9,287	1,510
Large Hotel	122,120	6	2,842	553
Large Office	498,588	12	6,244	1,580
Medium Office	53,628	3	742	318
Mid-Rise Apartment	33,740	4	242	67
Outpatient	40,946	3	1,388	321
Primary School	73,960	1	888	328
Quick-Service Restaurant	2,500	1	194	39
Secondary School	210,887	2	3,193	1,178
Small Hotel	43,200	4	600	133
Small Office	5,500	1	66	19
Standalone Retail	24,962	1	327	104
Strip Mall	22,500	1	297	93
Supermarket	45,000	1	1,687	367
Warehouse	52,045	1	269	96


The simulated building data includes aggregated hourly load profiles for all electrical loads associated with each building and includes smaller loads such as plug loads. The total hourly electrical load of each building was entered into the System Advisor Model (SAM).<sup>2</sup> See Section 2.5 for SAM details. Figure 2 and Figure 3 show select examples for simulated hourly office load data during the last week of March and the second week of July, respectively.

---

<sup>2</sup> Demand charges are usually measured and billed according to 15- or 30-minute time increments. The lack of 15-minute data resolution for this analysis may present an overestimation of a PV system's ability to offset demand charges. This could occur if the hourly data masks or smoothes sub-hourly spikes and dips in demand and production.



**Figure 2. Simulated hourly load data for medium-sized office buildings during the last week of March**



**Figure 3. Simualted hourly load data for medium-sized office buildings during the second week of July**

## 2.3 Rate Data


A total of 207 rates from 52 utility companies were evaluated.<sup>3</sup> These rates were obtained from the online Utility Rate Database (URDB) on the OpenEI platform<sup>4</sup> and from utility tariff sheets. This study assumes that PV energy production is compensated at the retail electricity rate for all energy produced, up to 100% of the building's annual electricity usage.<sup>5</sup> The utilities offer various commercial rate structures for different load sizes and types. In this analysis, we consider standard rates and optional rates. A standard rate refers to a rate that a building would be subject to by default, based on applicability requirements such as peak demand, voltage requirements, or energy consumption. An optional rate refers to a rate that customers may choose in lieu of the standard rate option. Smaller loads typically have more rate choices than larger loads because smaller users may sometimes choose to be on rates designed and made mandatory for larger loads. In some cases, larger facilities with solar installations have the option to use rates designed for smaller facilities. Eligibility criteria were obtained for each rate evaluated and were considered when calculating utility bills for each building type. Figure 4 illustrates the eligibility range for 22 utility rates in California, based on building demand in kilowatts (kW). Some rates are not applicable to all buildings, and they were not considered in the rate and cost impact calculations, though they were still analyzed for reference purposes. For a complete list of utility rates evaluated and their respective eligibility requirements, see Appendix A.

---

<sup>3</sup> Although we evaluated 77 unique locations for the building load profiles, there are instances when two or more locations are served by the same utility company. Each of the 77 locations is served by one of the 52 utilities.

<sup>4</sup> Open Energy Information (OpenEI) is a knowledge-sharing online community dedicated to connecting people with the latest information and data on energy resources from around the world (<http://www.OpenEI.org>). OpenEI was created in partnership with the DOE and federal laboratories across the nation. OpenEI's URDB (<http://en.openei.org/wiki/Gateway:Utilities>) contains downloadable rate structure information from electric utilities around the United States.

<sup>5</sup> This arrangement is also known as net metering, which may not be available in all states or utilities. For a complete list of utilities participating in net-metering arrangements, see the Database of State Incentives for Renewables and Efficiency (DSIRE) (<http://www.dsireusa.org/>). In this analysis, PV production never exceeds 100% of the building's annual electricity usage.



**Figure 4. Example of applicability of electricity rates for commercial facilities in three utility service territories in California**

Various utility rate elements are used throughout the United States. The most common rate elements (Ong et al. 2010) include the following:

- **Customer Charge.** A fixed monthly charge that is independent of energy use. Customer charges typically range from \$10 for small businesses to over \$1,000 for large facilities.
- **Energy Charges.** Energy charges are rates based on energy consumption, usually in dollars per kilowatt-hour or cents per kilowatt-hour.



- **Demand charges.** Normally included with energy charges in applicable rate structures, demand charges charge customers for their peak power (kW) usage. Demand charges can also be fixed or vary by season or hour.
- **Flat rates.** Fixed cost of electricity that does not vary except for fuel cost adjustments and other fees.
- **Seasonal rates.** Rates that vary by season. A typical seasonal rate structure has a lower rate for winter months and a higher rate for summer months.
- **Time-of-use rates.** TOU or time-of-day rate structures usually vary 2–4 times a day. A typical TOU rate has a lower cost at night, a higher cost during the late afternoon, and an intermediate cost during the mornings and evenings. The term “on-peak” or “peak” is generally used to describe hours with higher prices, while “off-peak” is used to describe hours with lower prices.
- **Tiered or block rates.** Tiered rates typically refer to rates that increase with increasing electricity usage, while block rates typically refer to rates that decrease with increasing electricity usage. Block rates are most common in the form of energy charges; however, tiered demand charges are also used.

Utilities may combine multiple rate elements within a single rate structure. Demand charges are typically combined with other rate elements for commercial tariffs. Table 2 provides a summary of rate elements from the rates used in this report. For a complete list of utility rates evaluated and their respective rate type, see Appendix A.

**Table 2. Summary of Rate Types Used in This Study**

Rate Type	Flat/Seasonal	Demand Charge	TOU	Tiered
Number of Rates <sup>a</sup>	97	141	55	61

<sup>a</sup> Due to combinations of various rate elements, the sum of rates across all categories is greater than the number of rates we evaluated (207).

## 2.4 Solar Resource Data

The PV production data used in this analysis were simulated using the TMY3 dataset of the National Solar Radiation Database (Wilcox and Marion 2008). The TMY3 dataset is intended to represent a typical year’s weather and solar resource patterns, though the dataset does not consist of an actual representative year. Rather, TMY3 was created by combining data from multiple years.<sup>6</sup> The meteorological dataset was used as an input for SAM, which simulated hourly PV production for use in the financial calculations.

## 2.5 System Advisor Model and Technical Calculations

Developed by the National Renewable Energy Laboratory (NREL) in collaboration with Sandia National Laboratories and DOE, SAM is a performance and economic model designed to facilitate decision making and analysis for renewable energy projects (Gilman and Dobos 2012).

<sup>6</sup> For example, the month of January may be from one year (e.g., 1989) while February may be from another year (e.g., 1994). Each TMY3 file may contain data from up to 12 different years. Data was intentionally selected to be representative of typical meteorological conditions.



The TMY3 meteorological data was provided as an input for SAM, which uses a performance model and user-defined assumptions to simulate hourly PV generation data. The following assumptions were used when generating the PV performance data:

- Tilt of 15 degrees
- South facing (180-degree azimuth)
- A derate factor of 85%
- Annual degradation of 0.5%.

In addition to the meteorological data, hourly building load data and utility rate data were given as inputs for SAM. A rooftop PV system was simulated for various penetration levels ranging from 0% (no PV system) to 100% (PV system generates the same amount of energy as each building's annual electrical energy consumption<sup>7</sup>) in increments of 5%. PV penetration is defined as the percentage of a facility's annual electrical energy consumption that is met by a PV system. The value of the PV system's generation under various penetration levels and rate structures was evaluated by comparing the buildings' annual electricity costs both with and without the PV system in each scenario. Any resulting difference from the comparison was attributed to the PV system.

## 2.6 Bill Savings and Solar Value Calculations


Solar value provides insight into the value of the energy the system is generating. Solar value is calculated as follows:

$$\text{Solar value } \left( \$/\text{kWh} \right) = \frac{\text{Bill reduction}}{\text{Solar generation}}$$

Figure 5 illustrates the value of a rooftop PV system on a secondary school building using Pacific Gas & Electric (PG&E) rates under different penetration levels. Rate A-6 yields the greatest solar value at \$0.23/kWh, far above the other rate structures. Rate A-6 is a very expensive rate, with summer afternoon prices approaching \$0.45/kWh. Although this gives high value to a PV system, a school switching to this rate from a less-expensive rate experiences an increase in total electricity cost, causing net losses rather than savings. Evaluating a rate structure in isolation without considering net bill impacts or other rate structure options is insufficient when conducting a rate analysis.

---

<sup>7</sup> Although the PV system generates the equivalent of 100% of the building's annual electricity consumption, there will be times that the PV system exports energy to the grid (afternoons) and times that the building imports energy (nights). Existing net-metering policies typically allow excess generation to be credited toward the following month's bill, effectively allowing the generation to be compensated, up to 100% of annual consumption, at retail rates.




**Figure 5. Value of PV generation under various rate structures and penetration levels for a school in the PG&E service territory**

In order to accurately assess the value of PV under each rate structure, it is necessary to compare the building's annual electricity costs without PV using the least-cost rate. The least-cost rate is the rate that minimizes annual electricity expense. This allows for the proper assessment of solar value in relation to the building's lowest cost option prior to the PV installation. This calculation can be expressed as the following equation:

$$\text{Net solar value } \left( \frac{\$}{\text{kWh}} \right) = \frac{\text{Lowest bill without solar} - \text{New rate bill with solar}}{\text{Solar generation}}$$

Figure 6 shows how the solar value chart changes once we employ the net solar value calculation method. This is a significant change from the previous chart, showing that rate A-6 is no longer the most attractive rate at all penetration levels. Many rates yield a negative value when PV penetration is small. This is because switching to these rates from rate A-10 (the best or least-expensive rate option without PV) increases the building's annual energy cost, despite having a small rooftop PV system. Though the PV system is still providing value to the building, it is not enough to overcome the increase in cost associated with switching to a more expensive rate. The result is a net annual loss for the building. At higher solar penetrations, the increase in solar value (under rates with high energy charges and high daytime rates) is enough to offset the cost increases from switching rates, yielding a net savings. All subsequent mentions of solar value or PV value in this paper refer to the *net solar value* metric above.



**Figure 6. Net value of PV generation under various rate structures and penetration levels for a school in the PG&E service territory**

It is important to note that we do not consider impacts of system cost in this analysis. Businesses may purchase the system with cash, finance the system through a loan, or use third-party financing such as a power purchase agreement (PPA) or solar lease. In order to assess the economic feasibility of a solar project, it is necessary to evaluate both the costs and benefits that the PV system provides over time. Several metrics that are used to evaluate economic performance of PV systems include, but are not limited to: break-even cost, internal rate of return, simple payback period, and net annual bill savings. Several reports have described or used these metrics to evaluate rooftop PV systems (Denholm et al. 2009; Ong and Denholm 2011; Short et al. 1995).

### 3 Results

The impact of rates, building types, solar penetration, and location was evaluated across 1,232 unique datasets. The aggregated results show trends across major categories. Furthermore, the aggregated results only consider the best rate choices: reported averages do not include results from sub-optimal rate options. Detailed results for each building type, location, and rate (including sub-optimal rate choices) are provided in Appendix A and Appendix C.

#### 3.1 Net Value of Solar

We examine the distribution of the net solar values calculated for PV penetration levels that yield the highest net solar value. Figure 7 compares the net solar value distribution with the distribution of electricity prices evaluated. On average, the solar value at each location is \$0.03 lower than the least-cost retail electricity rate without solar. The lower solar value is a result of the prevalence of demand charges in the rates used for this study. Seventy percent of all rates evaluated utilized demand charges, which typically reduce solar value (Ong et al. 2010).





Figure 7. Distribution of electricity prices and calculated solar values


Figure 8 shows the average solar value for all building types evaluated. Although solar value varies up to 30% by building type, the location is a bigger driver of solar value differences. Figure 9 shows the average solar value by location, with error bars designating differences due to building type. The primary driver of solar value by location is regional electricity price, and not

solar resource. For example, New Orleans’s solar resource is 13% greater than Green Bay, Wisconsin. Yet, the net solar value in Green Bay is 440% greater than in New Orleans.<sup>8</sup> Solar resource in the United States varies by less than a factor of 2, while our results indicate that solar value vary by more than a factor of 10.




**Figure 8. Average solar value for each building type**

<sup>8</sup> New Orleans is served by Entergy Louisiana, which utilizes commercial rates with high levels of demand charges. This causes a reduction in PV value. The high PV value in Green Bay is driven by Wisconsin Electric Power’s rate schedule Cg 6, which includes very high TOU energy rates.



**Figure 9a. Average solar value for the top 39 locations**


Note: Error bars designate the range of values resulting from building type differences.



**Figure 9b. Average solar value for the next 38 locations**

Note: Error bars designate the range of values resulting from building type differences.

Figure 10 shows the average solar value by six of the most common commercial rate structure combinations evaluated. On average, flat energy rates produce the highest solar value. Flat rate structures with demand charges reduce the average value by 17%. Tiered rates with demand charges result in a 21% reduction in value compared with energy-only tiered rates. TOU rates with demand charges, however, demonstrate a 6% increase in solar value compared with energy-only TOU rates.



**Figure 10. Solar value by rate type, averaged across all locations and building types evaluated**

### 3.2 Impact of PV Building Penetration

Building load profile, utility rate structure, and solar generation interact such that the value (per kilowatt-hour) that a PV system provides is dependent on PV penetration. PV penetration is defined as the percentage of a facility's annual electrical energy consumption that is met by a PV system. Table 3 shows the PV system size required to reach 100% penetration for each building type, averaged over all locations. Regions with higher solar insolation will require slightly smaller system capacities, and those with less sunlight will require larger capacities. For reference, the maximum rooftop penetration was estimated for each building type<sup>9</sup> and provides an approximate solar penetration value, should the PV installation be limited to the building's rooftop area. This analysis evaluates penetration levels from 0% to 100% because a building's PV system location is not limited to the rooftop area but may be installed on awnings, facades, parking garages, and other structures.<sup>10</sup>

<sup>9</sup> An estimate for maximum rooftop solar capacity is calculated by assuming a 14% module efficiency (140 Watts per square meter) and utilization of 50% of the total rooftop area (to account for potential obstructions due to HVAC equipment and other infrastructure.) Each building's rooftop area is assumed to be equivalent to the floor space area. For multi-story structures, the total rooftop area is assumed to be equivalent to the area of a single floor.

<sup>10</sup> Note that placing PV systems on facades and other structures with sub-optimal orientation are likely to have lower PV performance (James et al. 2011).




**Table 3. Average PV Penetration Values by Building Type**

<b>Building Type</b>	<b>Roof Area (m<sup>2</sup>)</b>	<b>Peak Power (kW)</b>	<b>Maximum Rooftop Solar<sup>a</sup> (kW)</b>	<b>100% Penetration Solar Size (kW)</b>	<b>Maximum Solar Energy Penetration</b>
Full-Service Restaurant	511	68	36	237	15.2%
Hospital	3,737	1,510	262	6,861	4.6%
Large Hotel	1,621	553	113	2,095	6.3%
Large Office	3,563	1,580	249	4,600	5.9%
Medium Office	1,661	318	116	549	21.1%
Mid-Rise Apartment	784	67	55	178	30.8%
Outpatient	1,268	321	89	1,023	8.7%
Primary School	6,871	328	481	654	73.6%
Quick-Service Restaurant	232	39	16	143	11.2%
Secondary School	9,796	1,178	686	2,341	29.3%
Small Hotel	1,003	133	70	443	15.8%
Small Office	511	19	36	49	73.6%
Standalone Retail	2,319	104	162	241	67.2%
Strip Mall	2,090	93	146	219	66.8%
Supermarket	4,181	367	293	1,245	23.5%
Warehouse	4,835	96	338	199	170.1%


<sup>a</sup> An estimate for maximum rooftop solar capacity is calculated assuming a 14% module efficiency and utilization of 50% of the total rooftop area (to avoid obstructions such as HVAC equipment.)

Our results indicate that in many cases, a single rate structure option has the highest solar value for all penetration levels. An example of this is shown in Figure 11 (for a strip mall in Houston, Texas), where rate GS provides the highest net solar value. The declining solar value with increasing penetration is due to the inability of solar generation to offset demand charges that occur during non-sunlight hours (Wiser et al. 2007). Figure 12 shows an example of one rate structure providing the highest solar value for low penetrations (rate A-10 TOU), while another rate structure becomes more valuable at higher penetrations (rate A-6). The scenario in Figure 11 shows that the highest solar value occurs at the smallest penetration, while Figure 12 shows the highest solar value at the maximum penetration.



**Figure 11. Net solar value with respect to penetration for all Entergy Texas rates evaluated**


Note: Dotted lines represent rates that are not applicable to this building and are included for reference purposes only.



**Figure 12. Net solar value with respect to penetration for all PG&E rates evaluated**


Note: Dotted lines represent rates that are not applicable to this building and are included for reference purposes only.

Figure 13 shows the distribution of optimal penetration levels for all locations and building types evaluated. The highest solar values occur at very small penetrations in 63% of cases, while they occur at maximum penetration 26% of the time. This pattern occurs because under most demand-based rates, smaller PV penetrations yield greater value (Wiser et al. 2007), while TOU rates favor large PV penetrations due to the coincidence of high rates and solar resource (Ong et al. 2010).



**Figure 13. Distribution of optimal penetration levels for all locations and building types evaluated**

It is important to note that the data in Figure 13 represent shallow optimums. Figure 14 compares all solar values relative to the highest solar value, averaged for all locations and buildings. Results indicate that even “least-optimal” penetration levels are still within 85% of the highest solar value at the optimum penetration.



**Figure 14. Comparison of solar values relative to the highest solar value, averaged for all locations and building types**

## 4 Conclusion

An evaluation of 16 different building types across 77 locations reveals that PV system value is highly dependent on the host building's rate structure. Although PV system economic performance may vary up to 30% by building type, regional electricity price differences are the primary driver of solar economics across the United States, causing solar value to vary by a factor of 10. System economics—under current net-metering rules—favor TOU rates and rates with little or no demand charges. This analysis found that there is often no single best rate. Rather, the most economical rate depends on PV penetration level with reference to the building electricity load. Optimal penetration levels are most often either very small (5%) or very large (100%), although penetration level effects are shown to exhibit shallow optimums.

These results identify general relationships between rate structures and PV installations on commercial buildings. This rate analysis applies to simulated load profiles (see Section 2.2) and is not intended to represent all buildings in the United States. Recommendations for future studies include identifying the impacts of potential changes in net-metering rules and evaluating additional sensitivities that have an impact on system economics, such as financing options and PV array orientation.

## References

Denholm, P.; Margolis, M.; Ong, S.; Roberts, B. (2009). *Break-Even Cost for Residential Photovoltaics in the United States: Key Drivers and Sensitivities*. NREL/TP-6A2-46909. Golden, CO: National Renewable Energy Laboratory.

Wilcox, S.; Marion, W. (2008). *Users Manual for TMY3 Data Sets*. NREL/TP-581-43156. Golden, CO: National Renewable Energy Laboratory.

Darghouth, N.; Barbose, G.; Wiser, R. (2010). *The Impact of Rate Design and Net Metering on the Bill Savings from Distributed PV for Residential Customers in California*. LBNL-3276E. Berkeley, CA: Ernest Orlando Lawrence Berkeley National Laboratory.

Gilman, P.; Dobos, A. (2012). *System Advisor Model, SAM 2011.12.2: General Description*. NREL/TP-6A20-53437. Golden, CO: National Renewable Energy Laboratory.

James, T.; Goodrich, A.; Woodhouse, M.; Margolis, R.; Ong, S. (2011) *Building-Integrated Photovoltaics (BIPV) in the Residential Sector: An Analysis of Installed Rooftop System Prices*. NREL/TP-6A20-53103. Golden, CO: National Renewable Energy Laboratory.

Ong, S.; Denholm, P.; Doris, E. (2010). *The Impacts of Commercial Electric Utility Rate Structure Elements on the Economics of Photovoltaic Systems*. NREL/TP-6A2-46782. Golden, CO: National Renewable Energy Laboratory.

Ong, S.; Denholm, P. (2011). *Maximizing the Value of Photovoltaic Installations on Schools in California: Choosing the Best Electricity Rates*. NREL/TP-6A2-51694. Golden, CO: National Renewable Energy Laboratory.

Short, W.; Packey, D.; Holt, T. (1995). *A Manual for the Economic Evaluation of Energy Efficiency and Renewable Energy Technologies*. NREL/TP-462-5173. Golden, CO: National Renewable Energy Laboratory.

Wilcox, S. (2007). *National Solar Radiation Database 1991 – 2005 Update: User's Manual*. NREL/TP-581-41364. Golden, CO: National Renewable Energy Laboratory.

Wiser, R.; Mills, A.; Barbose, G.; Golve, W. (2007). *The Impact of Retail Rate Structures on the Economics of Commercial Photovoltaic Systems in California*. LBNL-63019. Berkeley, CA: Ernest Orlando Lawrence Berkeley National Laboratory.

Deru, M.; Field, K.; Studer, D.; Benne, K.; Griffith, B.; Torcellini, P. (2011). *U.S. Department of Energy Commercial Reference Building Models of the National Building Stock*. NREL/TP-5500-46861. Golden, CO: National Renewable Energy Laboratory.

## Appendix A

**Table A-1. List of Utilities and Rates Evaluated With Information About Their Rate Type, Average Price Without Solar, Average Maximum Solar Value, and Applicable Range**

Utility	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
Alabama Power Co	LPSE		✓		✓	\$0.126	\$0.043	0-50
	LPME		✓		✓	\$0.082	\$0.057	50 and Up
	LPL		✓		✓	\$0.077	\$0.070	0-20,000
	LPLE		✓		✓	\$0.074	\$0.051	1,200-20,000
	BTA		✓	✓		\$0.095	\$0.034	0 and Up
	LPM		✓		✓	\$0.100	\$0.054	0 and Up
	SCH		✓		✓	\$0.077	\$0.069	0 and Up
Entergy Arkansas Inc	SGS		✓		✓	\$0.069	\$0.064	6-100
	LGS	✓	✓			\$0.070	\$0.063	100-1,000
	LGS-TOU		✓	✓		\$0.079	\$0.019	100-1,000
	LPS	✓	✓			\$0.062	\$0.057	1,000 and Up
	LPS-TOU		✓	✓		\$0.059	\$0.033	1,000 and Up
Salt River Project	E-32		✓	✓		\$0.073	\$0.016	0 and Up
	E-34			✓		\$0.082	\$0.013	0 and Up
	E-36		✓		✓	\$0.060	\$0.058	0 and Up
	E-61		✓	✓		\$0.053	\$0.021	417 and Up
	E-63			✓		\$0.055	\$0.041	417 and Up
	E-65			✓		\$0.050	\$0.033	1,000 and Up
Arizona Public Service Co	E-32 TOU (ES)			✓				0-20
	E-32 TOU (S)		✓	✓		\$0.116	\$0.101	21-100
	E-32 TOU M		✓	✓		\$0.124	\$0.106	101-400
	E-32 (L)	✓	✓			\$0.086	\$0.079	400 and Up
	E-32 TOU (L)		✓	✓		\$0.102	\$0.040	400 and Up
	SOLAR-3	✓				\$0.158	\$0.115	0 and Up
Pacific Gas & Electric Co	A-1	✓				\$0.176	\$0.181	0-200
	A-1TOU			✓		\$0.167	\$0.160	0-200
	A-6			✓		\$0.185	\$0.145	200 and Up
	A-10 TOU		✓	✓		\$0.113	\$0.129	200-499
	A-10	✓	✓			\$0.104	\$0.109	200-500
	E-19		✓	✓		\$0.109	\$0.119	500-1,000

Utility	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
	E-20		✓	✓		\$0.151	\$0.172	1,000 and Up
City of Los Angeles California (Utility Company)	A-SGS	✓	✓			\$0.154	\$0.178	0-30
	B-SGS		✓	✓		\$0.171	\$0.178	0-30
	A-2	✓	✓			\$0.127	\$0.098	30 and Up
	A-2 TOU		✓	✓		\$0.131	\$0.100	30 and Up
	A-SUB		✓	✓		\$0.126	\$0.081	30 and Up
	B-SUB	✓	✓			\$0.116	\$0.107	30 and Up
Southern California Edison Co	GS-1	✓				\$0.159	\$0.142	0-20
	GS-2-TOU-R		✓	✓		\$0.200	\$0.206	20-200
	GS-1-TOU	✓				\$0.177	\$0.134	20 and Up
	GS-3-TOU-R		✓	✓		\$0.140	\$0.107	200-500
	TOU-8-R		✓	✓		\$0.123	\$0.073	500 and Up
Public Service Co of Colorado	C	✓				\$0.095	\$0.099	0-25
	SG	✓	✓			\$0.083	\$0.032	0 and Up
	STOU	✓	✓			\$0.078	\$0.086	0 and Up
Connecticut Light & Power Co	27	✓	✓			\$0.173	\$0.196	0-350
	37	✓	✓			\$0.152	\$0.166	200-350
	56	✓	✓			\$0.161	\$0.135	350-1,000
	58	✓	✓			\$0.102	\$0.079	1,000 and Up
Delmarva Power & Light Co	SGS-S	✓						0-15
	MGS-S	✓	✓			\$0.079	\$0.070	15-300
	LGS-S		✓	✓		\$0.120	\$0.098	300 and Up
Florida Power & Light Co.	GS-1	✓						0-20
	GST-1			✓				0-20
	GSD-1	✓	✓			\$0.087	\$0.080	20-500
	GSDT-1		✓	✓		\$0.080	\$0.057	20-500
	GSLD-1	✓	✓			\$0.075	\$0.065	500-2,000
	GSLDT-1		✓	✓		\$0.084	\$0.100	500-2,000
Georgia Power Co	PLS-7				✓	\$0.138	\$0.132	0-30
	TOU-EO-6			✓	✓	\$0.168	\$0.112	0-30
	PLM-7				✓	\$0.119	\$0.101	30-500
	TOU-GSD-6		✓	✓		\$0.104	\$0.094	30-500
	PLL-7				✓	\$0.112	\$0.083	500 and Up
	TOU-SSD-6		✓	✓		\$0.093	\$0.091	500 and Up



Utility	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
MidAmerican Energy Co (Iowa)	GBS				✓	\$0.079	\$0.069	0-200
	GUS			✓		\$0.069	\$0.074	0-200
	LLS		✓		✓	\$0.043	\$0.057	200 and Up
	LNS		✓	✓		\$0.075	\$0.034	200 and Up
Idaho Power Co	sc7 SGS				✓			0-3
	sc9 LGS		✓		✓	\$0.053	\$0.050	3-1,000
	sc19 LPS		✓	✓		\$0.050	\$0.045	1,000 and Up
Commonwealth Edison Co	GSSL	✓	✓			\$0.108	\$0.069	0-100
	GSML	✓	✓			\$0.107	\$0.075	100-400
	GSLI	✓	✓			\$0.091	\$0.071	400-1,000
	GSVL	✓	✓			\$0.090	\$0.070	1,000-10,000
	WHDC	✓				\$0.094	\$0.096	0 and Up
Duke Energy Indiana Inc	LLF		✓	✓		\$0.098	\$0.094	0 and Up
	LLF-TOU				✓	\$0.109	\$0.080	0 and Up
Westar Energy Inc	SGS south		✓		✓	\$0.070	\$0.075	0 and Up
	MGS south	✓	✓			\$0.081	\$0.055	200 and Up
	HLF	✓	✓			\$0.081	\$0.044	1,000 and Up
Kentucky Utilities Co	GS	✓				\$0.078	\$0.093	0-50
	PS	✓	✓			\$0.085	\$0.072	50-250
	TODS	✓	✓			\$0.059	\$0.058	250-5,000
Entergy Louisiana Inc	LGS-21		✓		✓	\$0.045	\$0.051	0-3,000
	GS-1W		✓		✓	\$0.068	\$0.039	0 and Up
	MMRAS		✓		✓	\$0.063	\$0.020	0 and Up
Massachusetts Electric Co	G-1				✓	\$0.075	\$0.079	0 and Up
	G-2	✓	✓			\$0.095	\$0.065	0-200
	G-3	✓	✓			\$0.094	\$0.065	180 and Up
Baltimore Gas & Electric Co	SG	✓				\$0.101	\$0.060	0 and Up
	SGS	✓		✓		\$0.068	\$0.061	2.8 and Up
	SGL		✓	✓		\$0.104	\$0.065	60 and Up
Bangor Hydro-Electric Co	GS	✓				\$0.076	\$0.074	0-25
	MP	✓	✓			\$0.118	\$0.097	25 and Up
Detroit Edison Co	D3.4 TOU	✓				\$0.107	\$0.080	0 and Up
	D4 LGS		✓		✓	\$0.090	\$0.067	0 and Up
Northern States	A-12	✓				\$0.071	\$0.055	0-25

Utility	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
Power Co (Minnesota) Excel Energy	A-16	✓				\$0.087	\$0.049	0-25
	A-10	✓				\$0.090	\$0.069	0-25
	A-14	✓	✓			\$0.083	\$0.072	0-1,000
	A-15	✓	✓			\$0.087	\$0.055	0 and Up
	A-23	✓	✓			\$0.088	\$0.046	0-1,000
	A-24	✓	✓			\$0.086	\$0.075	0 and Up
Union Electric Co	2(M)	✓				\$0.091	\$0.070	0-100
	2(M)-TOD	✓				\$0.078	\$0.075	0-100
	3(M)		✓		✓	\$0.093	\$0.087	100 and Up
	3(M)-TOD		✓	✓	✓	\$0.095	\$0.083	100 and Up
Entergy Mississippi Inc	GS-295				✓	\$0.066	\$0.086	0 and Up
	B-31		✓		✓	\$0.068	\$0.090	200 and Up
	HLF-4		✓		✓	\$0.065	\$0.076	200 and Up
	C-26		✓		✓	\$0.061	\$0.065	1,000 and Up
	ALGS-7	✓	✓					5,000 and Up
North Western Corporation	GSEDS-1	✓				\$0.036	\$0.035	0 and Up
	GS-1	✓	✓			\$0.087	\$0.050	0 and Up
Duke Energy Carolinas LLC	SGS		✓		✓	\$0.093	\$0.042	0-75
	LGS		✓		✓	\$0.081	\$0.067	75 and Up
	OPT-G (NC)	✓	✓			\$0.076	\$0.074	0 and Up
Montana-Dakota Utilities Co (North Dakota)	SGES-20				✓	\$0.078	\$0.069	0-20
	SGTOD-25			✓		\$0.063	\$0.065	0-20
	GES-30	✓	✓			\$0.095	\$0.055	0 and Up
	GESTOD-31		✓	✓		\$0.090	\$0.061	0 and Up
Omaha Public Power District	GS-230				✓	\$0.036	\$0.024	0-50
	GS-231		✓		✓	\$0.052	\$0.039	50-1,000
	GS-232		✓		✓	\$0.030	\$0.019	1,000 and Up
Public Service Co of NH	G-OTOD	✓	✓			\$0.130	\$0.048	0 and Up
	G		✓		✓	\$0.128	\$0.090	0 and Up
	GV		✓		✓	\$0.133	\$0.088	0 and Up
	LG	✓	✓			\$0.131	\$0.080	0 and Up
Public Service Elec & Gas Co	BGS-FP		✓	✓		\$0.105	\$0.082	0-750
	LPL		✓	✓		\$0.106	\$0.084	150 and Up
Public Service Co	2A	✓				\$0.094	\$0.070	0-50

Utility of NM	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
	2B	✓				\$0.166	\$0.136	0-50
	3B		✓	✓		\$0.132	\$0.096	50 and Up
	3C		✓	✓		\$0.132	\$0.116	50 and Up
	4B		✓	✓		\$0.104	\$0.114	500 and Up
Nevada Power Co	GS	✓						0-5
	OGS-TOU	✓						0-5
	LGS-1	✓	✓			\$0.089	\$0.083	5-300
	LGS-2		✓	✓		\$0.073	\$0.072	300-1,000
	LGS-3		✓	✓		\$0.081	\$0.085	1,000 and Up
	LGS-X		✓	✓				25,000 and Up
Consolidated Edison Co-NY Inc	SC2-I				✓			0-10
	SC2-II			✓				0-10
	SC9-I	✓	✓			\$0.238	\$0.107	10-1,500
	SC9-III	✓	✓			\$0.163	\$0.092	10-1,500
	SC9-II	✓	✓			\$0.089	\$0.054	1,500 and Up
Ohio Power Co	GS-1	✓						0-10
	GS-2	✓	✓			\$0.096	\$0.062	10-8,000
	GS-TOD	✓				\$0.085	\$0.082	0-500
Oklahoma Gas & Electric Co	GS-1				✓	\$0.077	\$0.066	10-400
	GS-TOU				✓	\$0.067	\$0.069	10-400
	PL	✓	✓			\$0.064	\$0.074	400 and Up
	PL-TOU		✓	✓		\$0.058	\$0.054	400 and Up
PacifiCorp (Oregon)	23-200				✓	\$0.074	\$0.042	0-30
	23-210			✓		\$0.052	\$0.057	0-30
	28-200		✓		✓	\$0.078	\$0.068	31-200
	28-210	✓	✓		✓	\$0.093	\$0.066	31-200
	30-200	✓	✓		✓	\$0.092	\$0.068	201-999
	47-3,999 Self Generating	✓	✓			\$0.079	\$0.056	0-4,000
	47-4,000 Self Generating	✓	✓					4,000 and Up
PECO Energy Co	GS-2	✓	✓		✓	\$0.088	\$0.076	0-100
	GS-3		✓		✓	\$0.086	\$0.076	101-500
	GS-4		✓		✓	\$0.091	\$0.085	500 and Up
The Narragansett	C-06	✓	✓			\$0.125	\$0.028	0-200

Utility	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
Electric Co	G-02	✓	✓			\$0.056	\$0.041	10-200
	G-32	✓	✓			\$0.063	\$0.020	200 and Up
South Carolina Electric & Gas Co	9				✓	\$0.155	\$0.123	0 and Up
	20		✓		✓	\$0.124	\$0.095	75 and Up
	21		✓	✓		\$0.130	\$0.077	50-1,000
Black Hills Power Inc	GS		✓		✓	\$0.112	\$0.077	0 and Up
	GS (TE)		✓		✓	\$0.102	\$0.081	0 and Up
	GL				✓	\$0.080	\$0.077	125 and Up
City of Memphis Tennessee (Utility Company)	GSA			✓		\$0.100	\$0.099	0-5,000
	TDGSA		✓		✓	\$0.158	\$0.045	1,000-5,000
	TGSA	✓	✓			\$0.098	\$0.061	1,000-5,000
CPS Energy	PL				✓	\$0.063	\$0.068	0 and Up
	LLP		✓		✓	\$0.079	\$0.038	0 and Up
	ELP		✓		✓	\$0.060	\$0.042	1,000 and Up
Entergy Texas Inc.	SGS	✓						0-20
	GS	✓	✓			\$0.078	\$0.080	5-2,500
	GS-TOD		✓	✓		\$0.108	\$0.034	5-2,500
	LGS	✓	✓			\$0.065	\$0.057	300-2,500
	LGS-TOD		✓	✓		\$0.064	\$0.053	300-2,500
	LIPS	✓	✓					2,500 and Up
	LIPS-TOD	✓	✓					2,500 and Up
Moon Lake Electric Assn Inc (Utah)	GS-3	✓				\$0.085	\$0.101	0-49
	LP	✓	✓			\$0.072	\$0.069	50 and Up
Virginia Electric & Power Co	GS-1				✓	\$0.084	\$0.105	0-30
	GS-2	✓				\$0.104	\$0.063	30-500
	DP-2		✓	✓		\$0.066	\$0.087	30-500
	GS-2	✓	✓			\$0.072	\$0.079	500 and Up
Central Vermont Pub Serv Corp	Rate 10	✓				\$0.150	\$0.084	0 and Up
	Rate 2		✓		✓	\$0.133	\$0.123	0 and Up
Puget Sound Energy Inc	24	✓				\$0.099	\$0.102	0-50
	25		✓		✓	\$0.102	\$0.086	50-350
	26	✓	✓			\$0.094	\$0.083	350 and Up
Wisconsin Electric Power Co	Cg 1	✓						0-14
	Cg 2-A	✓	✓			\$0.116	\$0.105	14 and Up

Utility	Rate	Flat Seasonal	Demand	TOU	Tiered	Average Price	Average Solar Value	Applicability (kW)
	Cg 2-B	✓	✓			\$0.101	\$0.100	14-42
	Cg 3	✓	✓			\$0.131	\$0.069	42 and Up
	Cg 6-A	✓				\$0.135	\$0.144	0 and Up
	Cg 6-B	✓				\$0.138	\$0.133	0 and Up
Harrison Rural Elec Assn Inc	Sch B	✓				\$0.125	\$0.094	0-50
	C&1		✓		✓	\$0.075	\$0.068	50 and Up
Powder River Energy Corporation	GS	✓				\$0.070	\$0.063	0-50
	LP		✓		✓	\$0.058	\$0.050	50 and Up

## Appendix B

**Table B-1. Maximum Solar Value Found for Each Building Type in Each Location**

Location	Full-Service Restaurant	Hospital	Large Hotel	Large Office	Medium Office	Mid-Rise Apartment	Out Patient	Primary School	Quick-Service Restaurant	Secondary School	Small Hotel	Small Office	Standalone Retail	Strip Mall	Supermarket	Warehouse
Montgomery, AL	0.07	0.07	0.06	0.07	0.07	0.06	0.07	0.08	0.07	0.08	0.06	0.08	0.07	0.07	0.08	0.08
Little Rock, AR	0.06	0.05	0.04	0.05	0.06	0.06	0.06	0.08	0.06	0.07	0.04	0.07	0.07	0.07	0.07	0.06
Flagstaff, AZ	0.05	0.06	0.05	0.06	0.06	0.05	0.06	0.06	0.05	0.06	0.05	0.06	0.06	0.06	0.06	0.06
Phoenix, AZ	0.11	0.08	0.08	0.09	0.13	0.12	0.12	0.11	0.11	0.10	0.11	0.14	0.13	0.13	0.09	0.14
Tucson, AZ	0.11	0.08	0.08	0.10	0.13	0.12	0.12	0.11	0.11	0.11	0.11	0.13	0.13	0.13	0.11	0.14
Arcata, CA	0.19	0.18	0.19	0.19	0.20	0.19	0.18	0.19	0.19	0.21	0.19	0.19	0.18	0.18	0.19	0.19
Los Angeles, CA	0.11	0.09	0.09	0.09	0.12	0.09	0.11	0.13	0.11	0.13	0.09	0.12	0.11	0.12	0.12	0.10
San Francisco, CA	0.23	0.22	0.22	0.22	0.23	0.24	0.22	0.22	0.24	0.23	0.23	0.16	0.24	0.24	0.21	0.24
Boulder, CO	0.06	0.06	0.05	0.07	0.07	0.06	0.07	0.08	0.06	0.08	0.05	0.07	0.06	0.07	0.08	0.07
Eagle County, CO	0.06	0.06	0.06	0.07	0.07	0.06	0.07	0.08	0.06	0.08	0.06	0.07	0.07	0.07	0.07	0.07
Pueblo, CO	0.06	0.06	0.06	0.06	0.07	0.06	0.07	0.08	0.06	0.08	0.06	0.07	0.07	0.07	0.08	0.07
Bridgeport, CT	0.11	0.08	0.10	0.08	0.12	0.11	0.12	0.14	0.12	0.10	0.11	0.14	0.13	0.13	0.12	0.13
Wilmington, DE	0.06	0.09	0.07	0.09	0.11	0.06	0.10	0.13	0.06	0.13	0.05	0.08	0.08	0.08	0.12	0.08
Miami, FL	0.07	0.06	0.06	0.06	0.09	0.06	0.08	0.10	0.07	0.08	0.07	0.09	0.08	0.08	0.08	0.11
Tampa, FL	0.07	0.06	0.06	0.07	0.09	0.07	0.08	0.10	0.08	0.09	0.06	0.09	0.08	0.09	0.09	0.09
Atlanta, GA	0.09	0.08	0.10	0.10	0.11	0.10	0.09	0.12	0.10	0.12	0.09	0.14	0.11	0.11	0.10	0.11
Savannah, GA	0.09	0.08	0.09	0.10	0.11	0.10	0.09	0.11	0.10	0.11	0.09	0.13	0.11	0.11	0.10	0.11
Des Moines, IA	0.07	0.03	0.02	0.03	0.03	0.07	0.03	0.05	0.07	0.04	0.07	0.07	0.07	0.07	0.04	0.07
Mason, IA	0.07	0.03	0.02	0.03	0.03	0.07	0.03	0.04	0.07	0.04	0.07	0.07	0.07	0.07	0.04	0.07
Boise, ID	0.05	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.06	0.05	0.05	0.04	0.05
Chicago, IL	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
Springfield, IL	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
Indianapolis, IN	0.09	0.08	0.07	0.09	0.09	0.08	0.09	0.11	0.08	0.11	0.07	0.10	0.10	0.10	0.10	0.10
Goodland, KS	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.07	0.06	0.07	0.06	0.07	0.07	0.07	0.07	0.07
Wichita, KS	0.06	0.05	0.06	0.06	0.07	0.06	0.07	0.07	0.06	0.07	0.06	0.07	0.07	0.07	0.07	0.07
Lexington, KY	0.06	0.04	0.04	0.04	0.05	0.05	0.05	0.07	0.09	0.06	0.03	0.09	0.08	0.08	0.06	0.08
New Orleans, LA	0.04	0.02	0.02	0.02	0.03	0.04	0.02	0.03	0.04	0.02	0.03	0.08	0.04	0.04	0.02	0.04
Shreveport, LA	0.04	0.02	0.02	0.02	0.03	0.04	0.02	0.03	0.04	0.03	0.03	0.08	0.04	0.04	0.02	0.04
Boston, MA	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08

Location	Full-Service Restaurant	Hospital	Large Hotel	Large Office	Medium Office	Mid-Rise Apartment	Out Patient	Primary School	Quick-Service Restaurant	Secondary School	Small Hotel	Small Office	Standalone Retail	Strip Mall	Supermarket	Warehouse
Baltimore, MD	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08
Caribou, ME	0.09	0.09	0.08	0.10	0.10	0.09	0.10	0.12	0.09	0.12	0.09	0.07	0.10	0.11	0.12	0.10
Portland, ME	0.11	0.10	0.09	0.10	0.11	0.09	0.11	0.13	0.11	0.13	0.09	0.07	0.12	0.12	0.14	0.11
Detroit, MI	0.08	0.08	0.08	0.09	0.12	0.09	0.08	0.11	0.08	0.10	0.08	0.09	0.09	0.09	0.09	0.10
Houghton-Lake, MI	0.08	0.08	0.08	0.09	0.12	0.09	0.08	0.10	0.08	0.10	0.08	0.09	0.09	0.09	0.08	0.10
Traverse City, MI	0.08	0.08	0.08	0.09	0.12	0.09	0.08	0.09	0.08	0.10	0.08	0.09	0.09	0.09	0.09	0.10
International Falls, MN	0.07	0.07	0.06	0.07	0.09	0.06	0.07	0.09	0.07	0.09	0.06	0.09	0.08	0.08	0.08	0.08
Minneapolis, MN	0.07	0.07	0.06	0.07	0.09	0.06	0.08	0.09	0.07	0.08	0.06	0.09	0.08	0.07	0.08	0.08
Kansas City, MO	0.09	0.08	0.08	0.08	0.09	0.09	0.08	0.09	0.09	0.09	0.09	0.09	0.10	0.10	0.09	0.09
Jackson, MS	0.06	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.06	0.06	0.06	0.06
Billings, MT	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04
Greensboro, NC	0.07	0.06	0.06	0.07	0.07	0.06	0.08	0.10	0.06	0.10	0.06	0.09	0.08	0.09	0.08	0.08
Wilmington, NC	0.07	0.06	0.06	0.07	0.08	0.06	0.07	0.09	0.06	0.09	0.06	0.08	0.09	0.08	0.08	0.08
Bismarck, ND	0.07	0.07	0.06	0.08	0.09	0.07	0.09	0.10	0.08	0.11	0.06	0.09	0.10	0.10	0.10	0.09
Minot, ND	0.08	0.08	0.06	0.08	0.09	0.08	0.09	0.11	0.08	0.11	0.06	0.09	0.10	0.10	0.10	0.10
Omaha, NE	0.05	0.04	0.05	0.05	0.06	0.05	0.06	0.06	0.08	0.07	0.05	0.09	0.06	0.06	0.06	0.06
Concord, NH	0.11	0.11	0.10	0.11	0.12	0.11	0.12	0.13	0.12	0.13	0.11	0.13	0.12	0.12	0.13	0.12
Atlantic City, NJ	0.10	0.11	0.10	0.11	0.12	0.09	0.11	0.13	0.11	0.12	0.09	0.12	0.12	0.12	0.12	0.11
Albuquerque, NM	0.12	0.09	0.12	0.09	0.13	0.12	0.13	0.14	0.17	0.11	0.12	0.16	0.13	0.13	0.13	0.13
Las Vegas, NV	0.07	0.07	0.06	0.07	0.08	0.07	0.07	0.08	0.07	0.08	0.07	0.08	0.08	0.08	0.08	0.08
Reno, NV	0.07	0.07	0.06	0.07	0.08	0.07	0.08	0.09	0.07	0.09	0.07	0.09	0.08	0.08	0.08	0.08
New York, NY	0.09	0.05	0.09	0.06	0.12	0.11	0.09	0.16	0.08	0.16	0.09	0.11	0.12	0.12	0.15	0.13
Rochester, NY	0.09	0.06	0.09	0.05	0.12	0.11	0.09	0.20	0.08	0.17	0.09	0.14	0.12	0.12	0.15	0.12
Syracuse, NY	0.09	0.05	0.09	0.06	0.12	0.11	0.09	0.17	0.08	0.16	0.09	0.14	0.12	0.12	0.14	0.12
Cleveland, OH	0.08	0.09	0.07	0.09	0.08	0.08	0.08	0.08	0.08	0.11	0.08	0.08	0.08	0.08	0.08	0.08
Oklahoma City, OK	0.07	0.05	0.05	0.05	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
Burns, OR	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.06	0.02	0.07	0.07	0.06	0.07
Portland, OR	0.07	0.05	0.05	0.06	0.07	0.06	0.07	0.08	0.06	0.08	0.06	0.02	0.07	0.07	0.07	0.07
Philadelphia, PA	0.08	0.09	0.08	0.09	0.09	0.08	0.09	0.10	0.08	0.10	0.08	0.09	0.09	0.09	0.09	0.09
Pittsburgh, PA	0.09	0.09	0.08	0.09	0.09	0.08	0.09	0.10	0.08	0.11	0.08	0.10	0.09	0.09	0.10	0.09
Providence, RI	0.05	0.07	0.07	0.07	0.07	0.05	0.08	0.08	0.05	0.08	0.05	0.06	0.05	0.05	0.08	0.05
Charleston, SC	0.14	0.11	0.12	0.13	0.14	0.15	0.13	0.16	0.16	0.14	0.13	0.16	0.14	0.14	0.14	0.15
Pierre, SD	0.10	0.08	0.08	0.08	0.08	0.09	0.08	0.08	0.10	0.08	0.09	0.11	0.10	0.10	0.08	0.10

Location	Full-Service Restaurant	Hospital	Large Hotel	Large Office	Medium Office	Mid-Rise Apartment	Out Patient	Primary School	Quick-Service Restaurant	Secondary School	Small Hotel	Small Office	Standalone Retail	Strip Mall	Supermarket	Warehouse
Memphis, TN	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
Nashville, TN	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
Amarillo, TX	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.06	0.06	0.06	0.06
El Paso, TX	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.06	0.06	0.06	0.06
Houston, TX	0.07	0.05	0.04	0.05	0.08	0.07	0.06	0.07	0.07	0.07	0.06	0.08	0.07	0.07	0.07	0.08
Cedar City, UT	0.05	0.05	0.04	0.06	0.06	0.04	0.06	0.08	0.06	0.07	0.04	0.06	0.06	0.06	0.06	0.06
Salt Lake City, UT	0.05	0.05	0.04	0.05	0.06	0.04	0.06	0.07	0.06	0.07	0.04	0.06	0.06	0.06	0.06	0.06
Richmond, VA	0.07	0.03	0.01	0.03	0.07	0.07	0.07	0.08	0.07	0.07	0.07	0.06	0.07	0.07	0.07	0.07
Burlington, VT	0.11	0.10	0.09	0.11	0.11	0.12	0.10	0.13	0.12	0.13	0.10	0.15	0.11	0.12	0.12	0.12
Seattle, WA	0.09	0.08	0.07	0.09	0.08	0.09	0.08	0.09	0.10	0.10	0.08	0.10	0.09	0.09	0.08	0.09
Yakima, WA	0.09	0.08	0.07	0.08	0.08	0.09	0.08	0.09	0.10	0.09	0.08	0.10	0.09	0.09	0.09	0.09
Green Bay, WI	0.15	0.15	0.15	0.14	0.15	0.15	0.14	0.14	0.15	0.14	0.15	0.15	0.13	0.13	0.14	0.15
Charleston, WV	0.06	0.06	0.06	0.06	0.07	0.06	0.07	0.08	0.14	0.08	0.06	0.14	0.07	0.07	0.07	0.07
Elkins, WV	0.06	0.06	0.06	0.06	0.07	0.06	0.07	0.08	0.14	0.08	0.06	0.14	0.07	0.07	0.07	0.07
Cheyenne, WY	0.05	0.05	0.04	0.05	0.05	0.04	0.05	0.06	0.06	0.06	0.04	0.06	0.05	0.05	0.06	0.05



## Appendix C: Digital Appendix

The digital appendix includes detailed charts and tables for each location, building type, and rate structure evaluated.

[http://en.openei.org/wiki/Impact\\_of\\_Utility\\_Rates\\_on\\_PV\\_Economics\\_-\\_Digital\\_Appendix](http://en.openei.org/wiki/Impact_of_Utility_Rates_on_PV_Economics_-_Digital_Appendix)