

This report has been prepared  
for information and record  
purposes and is not to be referenced  
in any publication.

# NATIONAL BUREAU OF STANDARDS REPORT

8926

REPORT OF VISIT TO BRITISH FIRE RESEARCH STATION  
5 and 6 JULY 1965

By

A. F. Robertson



U. S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS

## THE NATIONAL BUREAU OF STANDARDS

The National Bureau of Standards is a principal focal point in the Federal Government for assuring maximum application of the physical and engineering sciences to the advancement of technology in industry and commerce. Its responsibilities include development and maintenance of the national standards of measurement, and the provisions of means for making measurements consistent with those standards; determination of physical constants and properties of materials; development of methods for testing materials, mechanisms, and structures, and making such tests as may be necessary, particularly for government agencies; cooperation in the establishment of standard practices for incorporation in codes and specifications; advisory service to government agencies on scientific and technical problems; invention and development of devices to serve special needs of the Government; assistance to industry, business, and consumers in the development and acceptance of commercial standards and simplified trade practice recommendations; administration of programs in cooperation with United States business groups and standards organizations for the development of international standards of practice; and maintenance of a clearinghouse for the collection and dissemination of scientific, technical, and engineering information. The scope of the Bureau's activities is suggested in the following listing of its four Institutes and their organizational units.

**Institute for Basic Standards.** Applied Mathematics. Electricity. Metrology. Mechanics. Heat. Atomic Physics. Physical Chemistry. Laboratory Astrophysics.\* Radiation Physics. Radio Standards Laboratory.\* Radio Standards Physics; Radio Standards Engineering. Office of Standard Reference Data.

**Institute for Materials Research.** Analytical Chemistry. Polymers. Metallurgy. Inorganic Materials. Reactor Radiations. Cryogenics.\* Materials Evaluation Laboratory. Office of Standard Reference Materials.

**Institute for Applied Technology.** Building Research. Information Technology. Performance Test Development. Electronic Instrumentation. Textile and Apparel Technology Center. Technical Analysis. Office of Weights and Measures. Office of Engineering Standards. Office of Invention and Innovation. Office of Technical Resources. Clearinghouse for Federal Scientific and Technical Information.\*\*

**Central Radio Propagation Laboratory.\*** Ionospheric Telecommunications. Tropospheric Telecommunications. Space Environment Forecasting. Aeronomy.

---

\* Located at Boulder, Colorado 80301.

\*\* Located at 5285 Port Royal Road, Springfield, Virginia 22171.

# NATIONAL BUREAU OF STANDARDS REPORT

NBS PROJECT

NBS REPORT

42102-12-4212120

July 12, 1965

8926

## REPORT OF VISIT TO BRITISH FIRE RESEARCH STATION 5 and 6 JULY 1965

By

A. F. Robertson

### IMPORTANT NOTICE

NATIONAL BUREAU OF STANDARDS  
for use within the Government.  
and review. For this reason, the  
whole or in part, is not authentic  
Bureau of Standards, Washington  
the Report has been specifically

Approved for public release by the  
Director of the National Institute of  
Standards and Technology (NIST)  
on October 9, 2015.

These accounting documents intended  
to be subjected to additional evaluation  
and listing of this Report, either in  
the Office of the Director, National  
Bureau of Standards, or by the Government agency for which  
copies for its own use.



U. S. DEPARTMENT OF COMMERCE  
NATIONAL BUREAU OF STANDARDS



REPORT OF VISIT TO BRITISH FIRE RESEARCH STATION  
5 and 6 JULY 1965

By

A. F. Robertson

ABSTRACT

The workers at the Fire Research Station have made significant progress in study of smoke production by diffusion flames and the influence of  $N_2$ ,  $CO_2$ , and  $H_2O$  as additives on the air side. Work on experimental burn out tests has progressed well and preliminary results suggest that the findings may tend to justify rather than discredit the standard time-temperature curve as a basis for fire testing. Elaborate heat flux instrumentation has been involved in these tests with the objective of deriving a heat balance for the fires.

Work on thermal decomposition products has not developed well because of staffing problems. The program for study of fire performance of prestressed concrete beams has been initiated. This includes study of the influence of continuity over supports on the behavior of such structures. I saw one of the first of these tests. It appears unlikely that continuity without axial restraint will provide much benefit with respect to fire endurance.

Introduction


Advantage was taken of the need to be in London in connection with a meeting of the IMCO group concerned with fire tests for marine constructions to visit the Fire Research Station for two days. This report summarizes the observations made during this visit and describes some work of special interest to us in connection with our current program plans.

\* \* \* \*

I visited Messrs. Ashton and Malhotra to discuss their work on doors and burn-out tests. Their work on doors is being done primarily for ISO and they are exploring ways of measuring hot gas passage through doors by use of a flat canopy over the unexposed surface as shown. They had set alumina plates into the canopy; these were fitted with both copper disc thermocouples as well as an adjacent thermocouple to measure air or gas temperature. Malhotra had considered the incorporation of a photometer, but this has not been done yet. They find that temperature measured at point B tends to be higher than at point A. They, like we, are inclined to favor a radiation measurement of heat transfer through the door.








The work on the British Iron and Steel Federation burn-out tests has been assigned to another group under Mr. Butcher who was ill during my visit. His assistant, Mr. Chitty, showed me some of their results. The tests are being conducted in a specially built structure as shown in the sketch. The position of cribs is shown for the usual test in which  $\frac{1}{3}$  of the floor area is covered. A few tests are also planned in which the fuel will be distributed over  $\frac{2}{3}$  of the floor area. The cribs are built up of nominal 2 in. x 2 in. x 3- $\frac{1}{2}$  ft sticks without fastening or gluing. They are arranged with single stick spacing and built to a height sufficient to provide the required fire load which has included 1- $\frac{1}{2}$ , 3, 6, and 12 lb/ft<sup>2</sup> of gross floor area. The cribs marked with an X are supported on three ring dynamometers which are located in a tube set into the floor. The cribs are all lit with kerosene-soaked fiberboard strips to start all together. Tests have been conducted with two ventilation arrangements, the windows wide open or half closed. The window area is equal to one half that of the wall in which they are set. Their height is 6 feet. They are unglazed and open from the start of the test.








Thomas and Hesselden have installed various special instrumentation as follows:

1. Vermiculite plaster heat flux meter on end wall. Thermocouples are located at the surface and  $1/4$  and  $1/2$  in. below.
2. A special copper constantan heat flux meter within and near one pile at four elevations. These are mounted on the surface of a water-cooled copper pipe.
3. In addition to the thermocouples located 3 in. below the ceiling, they have introduced additional couples at about 2 and 6 feet down.
4. An aspirating thermocouple is placed through the back wall.
5. Both a McGuire radiometer and a radiation pyrometer are set to view the flames through the window.



Results are still in process of being analyzed, but the following summary seems to be indicated:



1. In general, the damage to protective covering for steel seems more severe than that produced by a fire test of similar duration in a furnace.
2. The six-pound fire load exposure provides a severe fire and will require good protection for structural steel.
3. As sketched from memory after study of a collection of time-temperature curves, the data were about as follows:



In general, the tests with 1/4 window area seemed to provide the most severe exposure although peak temperatures were somewhat less.

4. Measurements had been made following Ingberg's suggestion that the severity could be assessed by measuring the area below the curve above base temperatures of 150 and 300°F. The following plots show, roughly, the results obtained and apparently justify the use of the standard time-temperature curve.






5. Winds had caused trouble during a few tests resulting in unusual circulation of air in the room during which one or more cribs did not burn with the others.
6. Although data were not well analyzed, it appeared that there would not be wide ( $> \pm 20\%$ ) variations in crib burning rate except for the situation of unusual wind effects.
7. The aspirating thermocouple did not appear to be too useful. Results were quite similar to those with bare thermocouples except for the period after flaming had ceased.
8. The objective of Thomas and Hesselden was to develop a heat balance for the system. Anemometer measurements were not too successful and window air flow would be based on geometry and room temperatures.
9. The basic series to explore fire load and ventilation had been completed, but additional tests were planned to study the influence of thermal properties of wall lining on severity.
10. Difficulty had been encountered in properly burning the cribs involved in the 1-1/2 lb/sq ft floor area. Probably because of the poor height to width ratio of the cribs.






Mr. Ashton and Malhotra had a test of a prestressed concrete beam in progress during our visit:



Two prestress cables were used, one for positive moments and the other for negative moments. I saw the specimen at about 3 hours after the start of test. It was nearly straight at that time, but cracks had developed across the top slab over the supports, probably a result of expansion of the web. The specimen failed apparently in compression over one of the supports at about 4-3/4 hr. A somewhat similar construction, but simply supported at the ends without continuity had failed at just over 4 hours. Apparently, performance was not significantly increased by continuity. These tests were being conducted for the Building Research Station. The specimens had aged for about 2 years indoors prior to test.



I visited Dr. Rashbash and Mr. Stark, his assistant. The work on study of smoke production from diffusion flames by Dr. McClintock had started off very well and is covered in his reports FR Note 570, 582 and 592. He found that soot formation of ethylene diffusion flames could be reduced by dilution of the air by  $N_2$ ,  $H_2O$ , and  $CO_2$ . The latter two gases apparently being most effective. These results seem to confirm the findings we have made on smoke production of cellulosic materials with  $N_2$  as diluent. McClintock's work has been terminated by his resignation.

Dr. Rashbash called my attention to the report, "Recirculation and Fuel Air Mixing as Related to Oil Burner Design" by Cooper, Kamo, Marek and Salbing, API Pub 1723, also, "Atmosphere from Fires in Rooms with Little Ventilating" by A. J. Kelly, FR Note No. 494.

Mr. Stark's work on smoke and decomposition product production from cellulosic and plastic materials in enclosures has also suffered by resignations. Apparently, work on cellulosic materials is nearing completion. The







