

# Data Center Optimization Strategies

Otto Van Geet, PE, NREL  
7X24 Exchange International Fall 2019 Conference  
Phoenix, Arizona  
October 27-30, 2019

NREL/PR-7A40-74841



# NREL Data Center Design

- **Showcase Facility**

- ESIF 182,000 ft.<sup>2</sup> research facility
- 10,000 ft.<sup>2</sup> data center
- 10 MW at full buildout
- LEED Platinum facility, PUE ≤ 1.06
- No mechanical cooling (eliminates expensive and inefficient chillers)



- **Data Center Features**

- Direct, component-level liquid cooling, 24°C (75°F) cooling water supply
- 35°C–40°C (95°F–104°F) return water (waste heat), captured and used to heat offices and lab space
- Pumps more efficient than fans
- High voltage 480 VAC power distribution directly to high power density 60kW–80 kW compute racks

- **Compared to a Typical Data Center**

- Lower CapEx—costs less to build
- Lower OpEx—efficiencies save

*Integrated “Chips to Bricks” Approach*

*Utilize the bytes and the BTUs!*

# Liquid Cooling – Considerations

- Liquid cooling essential at high-power density
- Compatible metals and water chemistry is crucial
- Redundancy in hydronic system (pumps, heat exchangers)
- Plan for hierarchy of systems
  - Cooling in series rather than parallel
  - Most sensitive systems get coolest liquid
- **At least 95% of rack heat load captured directly to liquid**

# Air-Cooled to Liquid-Cooled Racks

Traditional **air-cooled** allow for rack power densities of 1kW–5kW




**Liquid-cooled** when rack power densities in 5kW–80kW range, have several options




# Liquid-Cooled Server Options


**Peregrine HPC Tray**





**Cold Plates**




# Fanless Liquid-Cooled Server Options



Fixed Plate




Direct Immersion




# Metrics

$$PUE = \frac{\text{“Facility energy”} + \text{“IT energy”}}{\text{“IT energy”}}$$

$$ERE = \frac{\text{“Facility energy”} + \text{“IT energy”} - \text{“Reuse energy”}}{\text{“IT energy”}}$$




Assume ~20MW HPC system & \$1M per MW year utility cost.



# Metrics

$$WUE = \frac{\text{“Annual Site Water Usage”}}{\text{“IT energy”}}$$

the units of WUE are liters/kWh



$$WUE_{SOURCE} = \frac{\text{“Annual Site Water Usage”} + \text{“Annual Source Energy Water Usage”}}{\text{“IT energy”}}$$

$$WUE_{SOURCE} = \frac{\text{“Annual Site Water Usage”}}{\text{“IT energy”}} + [EWIF \times PUE]$$

where EWIF is energy water intensity factor



# Air- and Water-Cooled System Options

- **Air-Cooled System**

- Operation is based on DRY BULB temperature
- Consumes no water (no evaporative cooling)
- Large footprint requires very large airflow rates


- **Water-Cooled System**

- Operation is based on the lower WET BULB temperature
- Evaporative cooling process uses water to improve cooling efficiency
  - 80% LESS AIRFLOW = lower fan energy
  - Lower cost and smaller footprint
- Colder heat rejection temperatures improve system efficiency




*However, water-cooled systems depend on a reliable, continuous source of water.*



# Traditional Wet Cooling System



# Basic Hybrid System Concept



# Improved WUE—Thermosyphon



# ESIF Data Center Efficiency Dashboard



## ESIF HIGH PERFORMANCE COMPUTING DATA CENTER

As of Thu Aug 1 16:04:11 MDT 2019

**OUTDOOR**


Air Temperature **72.3°F**  
Relative Humidity **55.0%**

$$PUE = \frac{\text{Facility power} + \text{IT power}}{\text{IT power}} = \frac{46.42 \text{ kW} + 949.81 \text{ kW}}{949.81 \text{ kW}} = 1.049$$

$$ERE = \frac{\text{Facility power} + \text{IT power} - \text{Re-use}}{\text{IT power}} = \frac{46.42 \text{ kW} + 949.81 \text{ kW} - (-0.20 \text{ kW})}{949.81 \text{ kW}} = 1.049$$

### Where is the Data Center Waste Energy Going?

ESIF Building Heat	-0.2 kW
Outdoors via Thermosyphon	141.2 kW
Outdoors via Cooling Towers	803.9 kW
Campus Building Heat	0.0 kW





HPC CDUs		
ROW	In	Out
2	0.0°F	0.0°F
7	69.8°F	101.7°F
8	69.1°F	101.8°F

<https://hpc.nrel.gov/cool/>

Any application using an open cooling tower is a potential application for a hybrid cooling system, but certain characteristics will increase the potential for success.

- **Favorable Application Characteristics**
  - Year-round heat rejection load (24/7, 365 days is best)
  - Higher loop temperatures relative to average ambient temperatures
  - High water and wastewater rates or actual water restrictions
  - Owner's desire to mitigate risk of future lack of continuous water availability (water resiliency)
  - Owner's desire to reduce water footprint to meet water conservation targets

# Sample Data: Typical Loads and Heat Sinks



# Data Center Metrics

## First Year of TSC Operation (9/1/16-8/31/17)

Hourly average IT Load = 888 kW


PUE = 1.034

ERE = 0.929


WUE = 0.7 liters/kWh

with only cooling towers, WUE = 1.42 liters/kWh

### Annual Heat Rejection



<https://www.nrel.gov/docs/fy18osti/72196.pdf>




$WUE_{SOURCE} = 5.4$  liters/kWh

$WUE_{SOURCE} = 4.9$  liters/kWh if energy from 720 kW PV (10.5%) is included

using EWIF 4.542 liters/kWh for Colorado

# Cost and Water Savings



# Contact

Otto VanGeet, 303-384-7369, [otto.vangeet@nrel.gov](mailto:otto.vangeet@nrel.gov)



**NREL PV Systems ~ 3,600 kW  
South Table Mesa Campus**

# Notice

---

This research was performed using computational resources sponsored by the U.S. Department of Energy's (DOE) Office of Energy Efficiency and Renewable Energy and located at the National Renewable Energy Laboratory under Contract No. DE-AC36-08G028308. Funding provided by the Federal Energy Management Program. The views expressed in the presentation do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the presentation for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.